

Modbus Register B7000i, B7000i Dairy

V1.1

B7000i, B7000i Dairy V1.1

Name	Register	Data Type	Length	Access Mode	Discrete Range	Min / Max	Description
find complete register list on the next pages	0		1				for B7000i Software min. V05.03.00



Be Right™

Modbus Register
B7000i & B7000i Dairy BioTector TOC
Analyzer
V 1.1

B7000i & B7000i Dairy BioTector TOC Analyzer V 1.1

REACTION RESULTS Registers

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_1_RLOG_TIC	40001	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: TIC Last on-line TIC reading
	40002					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_TOC	40003	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: TOC Last on-line TOC reading
	40004					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_TC	40005	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: TC Last on-line TC reading
	40006					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_VOC	40007	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: VOC Last on-line VOC reading
	40008					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_COD	40013	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: COD Last on-line COD reading
	40014					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_BOD	40015	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: BOD Last on-line BOD reading
	40016					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_LPI	40017	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: LPI Last calculated LPI result
	40018					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_LP	40019	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: LP Last calculated LP result
	40020					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_FLOW	40021	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: Flow Last flow meter reading
	40022					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_TW	40023	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: Total Waste Total waste result
	40024					Note: reading this register updates the value in its _TIME register.
STREAM_1_RLOG_CF	40027	Float	2	R	< -1.0e6,1.0e6 >	Stream 1: CF Last on-line CF reading
	40028					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_TIC	40029	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: TIC Last on-line TIC reading
	40030					Note: reading this register updates the value in its _TIME register.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_2_RLOG_TOC	40031	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: TOC Last on-line TOC reading
	40032					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_TC	40033	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: TC Last on-line TC reading
	40034					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_VOC	40035	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: VOC Last on-line VOC reading
	40036					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_COD	40041	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: COD Last on-line COD reading
	40042					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_BOD	40043	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: BOD Last on-line BOD reading
	40044					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_LPI	40045	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: LPI Last calculated LPI result
	40046					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_LP	40047	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: LP Last calculated LP result
	40048					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_FLOW	40049	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: Flow Last flow meter reading
	40050					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_TW	40051	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: Total Waste Total waste result
	40052					Note: reading this register updates the value in its _TIME register.
STREAM_2_RLOG_CF	40055	Float	2	R	< -1.0e6,1.0e6 >	Stream 2: CF Last on-line CF reading
	40056					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_TIC	40057	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: TIC Last on-line TIC reading
	40058					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_TOC	40059	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: TOC Last on-line TOC reading
	40060					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_TC	40061	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: TC Last on-line TC reading
	40062					Note: reading this register updates the value in its _TIME register.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_3_RLOG_VOC	40063	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: VOC Last on-line VOC reading
	40064					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_COD	40069	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: COD Last on-line COD reading
	40070					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_BOD	40071	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: BOD Last on-line BOD reading
	40072					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_LPI	40073	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: LPI Last calculated LPI result
	40074					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_LP	40075	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: LP Last calculated LP result
	40076					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_FLOW	40077	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: Flow Last flow meter reading
	40078					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_TW	40079	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: Total Waste Total waste result
	40080					Note: reading this register updates the value in its _TIME register.
STREAM_3_RLOG_CF	40083	Float	2	R	< -1.0e6,1.0e6 >	Stream 3: CF Last on-line CF reading
	40084					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_TIC	40085	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: TIC Last on-line TIC reading
	40086					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_TOC	40087	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: TOC Last on-line TOC reading
	40088					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_TC	40089	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: TC Last on-line TC reading
	40090					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_VOC	40091	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: VOC Last on-line VOC reading
	40092					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_COD	40097	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: COD Last on-line COD reading
	40098					Note: reading this register updates the value in its _TIME register.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_4_RLOG_BOD	40099	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: BOD Last on-line BOD reading
	40100					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_LPI	40101	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: LPI Last calculated LPI result
	40102					Note: reading this register updates the value in its _TIME register.
STREAM_4_RLOG_CF	40105	Float	2	R	< -1.0e6,1.0e6 >	Stream 4: CF Last on-line CF reading
	40106					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_TIC	40107	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: TIC Last on-line TIC reading
	40108					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_TOC	40109	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: TOC Last on-line TOC reading
	40110					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_TC	40111	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: TC Last on-line TC reading
	40112					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_VOC	40113	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: VOC Last on-line VOC reading
	40114					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_COD	40119	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: COD Last on-line COD reading
	40120					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_BOD	40121	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: BOD Last on-line BOD reading
	40122					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_LPI	40123	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: LPI Last calculated LPI result
	40124					Note: reading this register updates the value in its _TIME register.
STREAM_5_RLOG_CF	40127	Float	2	R	< -1.0e6,1.0e6 >	Stream 5: CF Last on-line CF reading
	40128					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_TIC	40129	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: TIC Last on-line TIC reading
	40130					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_TOC	40131	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: TOC Last on-line TOC reading
	40132					Note: reading this register updates the value in its _TIME register.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_6_RLOG_TC	40133	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: TC Last on-line TC reading
	40134					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_VOC	40135	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: VOC Last on-line VOC reading
	40136					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_COD	40141	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: COD Last on-line COD reading
	40142					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_BOD	40143	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: BOD Last on-line BOD reading
	40144					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_LPI	40145	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: LPI Last calculated LPI result
	40146					Note: reading this register updates the value in its _TIME register.
STREAM_6_RLOG_CF	40149	Float	2	R	< -1.0e6,1.0e6 >	Stream 6: CF Last on-line CF reading
	40150					Note: reading this register updates the value in its _TIME register.
RLOG_SMPL_STATUS	40200	Float	2	R	< 0.0,100.0 >	Sample status Quality of sample, measured by the ultrasonic sensor
	40201					Note: reading this register updates the value in its _TIME register.
RLOG_SMPL_STATUS_TIME	40202	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last Sample status reading
	40203					
STREAM_1_RLOG_TIC_TIME	40300	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line TIC reading
	40301					
STREAM_1_RLOG_TOC_TIME	40302	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line TOC reading
	40303					
STREAM_1_RLOG_TC_TIME	40304	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line TC reading
	40305					
STREAM_1_RLOG_VOC_TIME	40306	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line VOC reading
	40307					
STREAM_1_RLOG_COD_TIME	40312	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line COD reading
	40313					
STREAM_1_RLOG_BOD_TIME	40314	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line BOD reading
	40315					
STREAM_1_RLOG_LPI_TIME	40316	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last calculated LPI result
	40317					
STREAM_1_RLOG_LP_TIME	40318	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last calculated LP result. Note only 3 streams available
	40319					

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_1_RLOG_FLOW_TIME	40320	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last flow meter reading. Note only 3 streams available
	40321					
STREAM_1_RLOG_TW_TIME	40322	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last calculated total waste result. Note only 3 streams available
	40323					
STREAM_1_RLOG_CF_TIME	40326	integer	2	R	0x00000000-0xFFFFFFFF	Stream 1: Time, Date of last on-line CF reading
	40327					
STREAM_2_RLOG_TIC_TIME	40328	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line TIC reading
	40329					
STREAM_2_RLOG_TOC_TIME	40330	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line TOC reading
	40331					
STREAM_2_RLOG_TC_TIME	40332	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line TC reading
	40333					
STREAM_2_RLOG_VOC_TIME	40334	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line VOC reading
	40335					
STREAM_2_RLOG_COD_TIME	40340	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line COD reading
	40341					
STREAM_2_RLOG_BOD_TIME	40342	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line BOD reading
	40343					
STREAM_2_RLOG_LPI_TIME	40344	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last calculated LPI result
	40345					
STREAM_2_RLOG_LP_TIME	40346	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last calculated LP result. Note only 3 streams available
	40347					
STREAM_2_RLOG_FLOW_TIME	40348	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last flow meter reading. Note only 3 streams available
	40349					
STREAM_2_RLOG_TW_TIME	40350	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last calculated total waste result. Note only 3 streams available
	40351					
STREAM_2_RLOG_CF_TIME	40354	integer	2	R	0x00000000-0xFFFFFFFF	Stream 2: Time, Date of last on-line CF reading
	40355					
STREAM_3_RLOG_TIC_TIME	40356	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line TIC reading
	40357					
STREAM_3_RLOG_TOC_TIME	40358	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line TOC reading
	40359					
STREAM_3_RLOG_TC_TIME	40360	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line TC reading
	40361					
STREAM_3_RLOG_VOC_TIME	40362	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line VOC reading
	40363					
STREAM_3_RLOG_COD_TIME	40368	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line COD reading
	40369					
STREAM_3_RLOG_BOD_TIME	40370	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line BOD reading
	40371					
STREAM_3_RLOG_LPI_TIME	40372	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last calculated LPI result
	40373					

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_3_RLOG_LP_TIME	40374	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last calculated LP result. Note only 3 streams available
	40375					
STREAM_3_RLOG_FLOW_TIME	40376	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last flow meter reading. Note only 3 streams available
	40377					
STREAM_3_RLOG_TW_TIME	40378	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last calculated total waste result. Note only 3 streams available
	40379					
STREAM_3_RLOG_CF_TIME	40382	integer	2	R	0x00000000-0xFFFFFFFF	Stream 3: Time, Date of last on-line CF reading
	40383					
STREAM_4_RLOG_TIC_TIME	40384	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line TIC reading
	40385					
STREAM_4_RLOG_TOC_TIME	40386	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line TOC reading
	40387					
STREAM_4_RLOG_TC_TIME	40388	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line TC reading
	40389					
STREAM_4_RLOG_VOC_TIME	40390	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line VOC reading
	40391					
STREAM_4_RLOG_COD_TIME	40396	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line COD reading
	40397					
STREAM_4_RLOG_BOD_TIME	40398	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line BOD reading
	40399					
STREAM_4_RLOG_LPI_TIME	40400	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last calculated LPI result
	40401					
STREAM_4_RLOG_CF_TIME	40404	integer	2	R	0x00000000-0xFFFFFFFF	Stream 4: Time, Date of last on-line CF reading
	40405					
STREAM_5_RLOG_TIC_TIME	40406	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line TIC reading
	40407					
STREAM_5_RLOG_TOC_TIME	40408	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line TOC reading
	40409					
STREAM_5_RLOG_TC_TIME	40410	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line TC reading
	40411					
STREAM_5_RLOG_VOC_TIME	40412	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line VOC reading
	40413					
STREAM_5_RLOG_COD_TIME	40418	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line COD reading
	40419					
STREAM_5_RLOG_BOD_TIME	40420	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line BOD reading
	40421					
STREAM_5_RLOG_LPI_TIME	40422	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last calculated LPI result
	40423					
STREAM_5_RLOG_CF_TIME	40426	integer	2	R	0x00000000-0xFFFFFFFF	Stream 5: Time, Date of last on-line CF reading
	40427					
STREAM_6_RLOG_TIC_TIME	40428	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line TIC reading
	40429					

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
STREAM_6_RLOG_TOC_TIME	40430	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line TOC reading
	40431					
STREAM_6_RLOG_TC_TIME	40432	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line TC reading
	40433					
STREAM_6_RLOG_VOC_TIME	40434	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line VOC reading
	40435					
STREAM_6_RLOG_COD_TIME	40440	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line COD reading
	40441					
STREAM_6_RLOG_BOD_TIME	40442	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line BOD reading
	40443					
STREAM_6_RLOG_LPI_TIME	40444	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last calculated LPI result
	40445					
STREAM_6_RLOG_CF_TIME	40448	integer	2	R	0x00000000-0xFFFFFFFF	Stream 6: Time, Date of last on-line CF reading
	40449					



Be Right™

B7000i & B7000i Dairy BioTector TOC Analyzer V 1.1 SETTINGS, CALIBRATION AND DIAGNOSTICS Registers

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
DEVICE_ADDR	40500	integer	1	R/W	0x0000-0x00C8	Device address on Modbus network.
DEVICE_ID	40501	integer	1	R/W	0x0000-0xFFFF	Device class ID code.
MANUF_ID	40502	integer	1	R/W	0x0000-0x00FF	Manufacture ID code.
DEVICE_SERIAL_ID	40503	uint48	3	R	0x000000000000-0xFFFFFFFF	Device serial number.
	40504					
	40505					
PROTO_REV	40506	integer	1	R	0x0000-0x9999	Modbus protocol implementation revision, expressed in BCD code. rev AA.BB → 0xAABB
FRMW_REV	40507	integer	1	R	0x0000-0x9999	Device firmware revision, expressed in BCD code. rev AA.BB → 0xAABB
REGS_MAP_REV	40508	integer	1	R	0x0000-0x9999	Device Modbus registers map, expressed in BCD code. rev AA.BB → 0xAABB
LOCATION_STR	40509	string	8	R/W	max. 16chars	Device location text info. The string has to be null terminated if shorter than max. size.
	40510					
	40511					
	40512					
	40513					
	40514					
	40515					
40516						
BAUDRATE	40517	integer	1	R/W	0x0000-0x0008	Indexed device baud rate used on Modbus. 0 – 1200 bps 1 – 2400 bps 2 – 4800 bps 3 – 9600 bps 4 – 14400 bps 5 – 19200 bps 6 – 38400 bps 7 – 57600 bps 8 – 115200 bps Note: default value should be 7, 57600bps.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
SYS_TIMEDATE	40518	integer	2	R/W	0x00000000-0xFFFFFFFF	System time & date in seconds elapsed since 1.1.1970.
	40519					Note: this reg can be changed only when system is fully stopped.
SYS_TIME	40520	integer	1	R/W	0x0000-0x3B3B	System time, encoded in higher/lower bytes. HH:MM → 0xHMM Note: this reg can be changed only when system is fully stopped.
SYS_DATE	40521	integer	2	R/W	0x00000000-0x1F0C0833	System date, encoded in 4 bytes bytes. higher word DAY:MON → 0xDDMM lower word YEAR → 0xYYYY Note: this reg can be changed only when system is fully stopped.
	40522					
REACT_TIC_RANGE1	40550	Float	2	R	< 0.0,1000000.0 >	TIC range 1 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40551					
REACT_TIC_RANGE2	40552	Float	2	R	< 0.0,1000000.0 >	TIC range 2 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40553					
REACT_TIC_RANGE3	40554	Float	2	R	< 0.0,1000000.0 >	TIC range 3 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40555					
REACT_TOC_RANGE1	40556	Float	2	R	< 0.0,1000000.0 >	TOC range 1 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40557					
REACT_TOC_RANGE2	40558	Float	2	R	< 0.0,1000000.0 >	TOC range 2 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40559					
REACT_TOC_RANGE3	40560	Float	2	R	< 0.0,1000000.0 >	TOC range 3 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40561					

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
REACT_TC_RANGE1	40562	Float	2	R	< 0.0,1000000.0 >	TC range 1 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40563					
REACT_TC_RANGE2	40564	Float	2	R	< 0.0,1000000.0 >	TC range 2 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40565					
REACT_TC_RANGE3	40566	Float	2	R	< 0.0,1000000.0 >	TC range 3 Note: shown as 0.0 if in the actual analysis mode this result not available.
	40567					
OXF_ANLS	40586	integer	1	R	0x0000-0x07FF	Show the current oxidation analysis type. bit 0 = TIC+TOC. bit 1 = TC. bit 2 = VOC. bit 3 = TIC+TOCe bit 4 = TCe bit 5 = TIC+TOCb bit 6 = TCb bit 7 = VOCb bit 8 = Fast TC
AUTOCAL_PROG	40700	integer	1	R	0x0000-0x000F	bit 0 = off bit 1 = Monday bit 2 = Tuesday bit 3 = Wednesday bit 4 = Thursday bit 5 = Friday bit 6 = Saturday bit 7 = Sunday
AUTOCAL_PROG_TIME	40701	integer	1	R	0x0000-0x3B3B	Time of scheduled autocal, encoded in higher/lower bytes. HH:MM → 0xHHMM
CLOG_CAL_SELECT	40702	integer	1	R/W	0x0000-0x0004	0 = TIC 1 = TOC 2 = TC 3 = TN 4 = TP 5 = TPR Note: this register value defines value of all following CLOG_ registers. By writing into CLOG_CAL_SELECT register updates CLOG_ registers in the similar way the reading of CLOG_CALx_SPAN_STATUS or CLOG_CALx_ZERO does.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
CLOG_CAL1_SPAN_STATUS	40703	integer	1	R	0x0000-0x007F	<p>bit 0 = calibration bit 1 = check bit 2 = calibration successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = calculated from TOC/TC result bit 6 = entered by operator</p> <p>Note: in case of calibration failure on master range, the derived results status need to be update as well.</p>
CLOG_CAL1_SPAN_TIME	40704	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last calibration action
	40705					Note: this register value is only updated when CLOG_CAL1_SPAN_STATUS register is read.
CLOG_CAL1_SPAN_STD	40706	Float	2	R	< -1.0e6,1.0e6 >	Standard used Null if bits 4-6 set in "...status" register
	40707					Note: this register value is only updated when CLOG_CAL1_SPAN_STATUS register is read.
CLOG_CAL1_SPAN_RSLT	40708	Float	2	R	< -1.0e6,1.0e6 >	Result found Null if bits 4-6 set in "...status" register
	40709					Note: this register value is only updated when CLOG_CAL1_SPAN_STATUS register is read.
CLOG_CAL1_SPAN_FACTOR	40710	Float	2	R	< -1.0e6,1.0e6 >	Span adjustment factor currently in use
	40711					Note: this register value is only updated when CLOG_CAL1_SPAN_STATUS register is read.
CLOG_CAL1_ZERO_STATUS	40712	integer	1	R/W	0x0000-0x007F	<p>bit 0 = zero calibration bit 1 = zero check bit 2 = zero successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = TIC: no zero required bit 6 = entered by operator</p>
CLOG_CAL1_ZERO_TIME	40713	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last zero action
	40714					Note: this register value is only updated when CLOG_CAL1_ZERO_STATUS register is read.
CLOG_CAL1_ZERO_OFFSET	40715	Float	2	R	< -1.0e6,1.0e6 >	Zero offset currently in use
	40716					Note: this register value is only updated when CLOG_CAL1_ZERO_STATUS register is read.
CLOG_CAL2_SPAN_STATUS	40717	integer	1	R	0x0000-0x007F	<p>bit 0 = calibration bit 1 = check bit 2 = calibration successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = calculated from TOC/TC result bit 6 = entered by operator</p>

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
CLOG_CAL2_SPAN_TIME	40718	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last calibration action
	40719					Note: this register value is only updated when CLOG_CAL2_SPAN_STATUS register is read.
CLOG_CAL2_SPAN_STD	40720	Float	2	R	< -1.0e6,1.0e6 >	Standard used Null if bits 4-6 set in "...status" register
	40721					Note: this register value is only updated when CLOG_CAL2_SPAN_STATUS register is read.
CLOG_CAL2_SPAN_RSLT	40722	Float	2	R	< -1.0e6,1.0e6 >	Result found Null if bits 4-6 set in "...status" register
	40723					Note: this register value is only updated when CLOG_CAL2_SPAN_STATUS register is read.
CLOG_CAL2_SPAN_FACTOR	40724	Float	2	R	< -1.0e6,1.0e6 >	Span adjustment factor currently in use
	40725					Note: this register value is only updated when CLOG_CAL2_SPAN_STATUS register is read.
CLOG_CAL2_ZERO_STATUS	40726	integer	1	R/W	0x0000-0x007F	bit 0 = zero calibration bit 1 = zero check bit 2 = zero successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = TIC: no zero required bit 6 = entered by operator
CLOG_CAL2_ZERO_TIME	40727	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last zero action
	40728					Note: this register value is only updated when CLOG_CAL2_ZERO_STATUS register is read.
CLOG_CAL2_ZERO_OFFSET	40729	Float	2	R	< -1.0e6,1.0e6 >	Zero offset currently in use
	40730					Note: this register value is only updated when CLOG_CAL2_ZERO_STATUS register is read.
CLOG_CAL3_SPAN_STATUS	40731	integer	1	R	0x0000-0x007F	bit 0 = calibration bit 1 = check bit 2 = calibration successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = calculated from TOC/TC result bit 6 = entered by operator
CLOG_CAL3_SPAN_TIME	40732	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last calibration action
	40733					Note: this register value is only updated when CLOG_CAL3_SPAN_STATUS register is read.
CLOG_CAL3_SPAN_STD	40734	Float	2	R	< -1.0e6,1.0e6 >	Standard used Null if bits 4-6 set in "...status" register
	40735					Note: this register value is only updated when CLOG_CAL3_SPAN_STATUS register is read.
CLOG_CAL3_SPAN_RSLT	40736	Float	2	R	< -1.0e6,1.0e6 >	Result found Null if bits 4-6 set in "...status" register
	40737					Note: this register value is only updated when CLOG_CAL3_SPAN_STATUS register is read.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
CLOG_CAL3_SPAN_FACTOR	40738	Float	2	R	< -1.0e6,1.0e6 >	Span adjustment factor currently in use
	40739					Note: this register value is only updated when CLOG_CAL3_SPAN_STATUS register is read.
CLOG_CAL3_ZERO_STATUS	40740	integer	1	R/W	0x0000-0x007F	bit 0 = zero calibration bit 1 = zero check bit 2 = zero successful bit 3 = result outside band bit 4 = calculated from other range bit 5 = TIC: no zero required bit 6 = entered by operator
CLOG_CAL3_ZERO_TIME	40741	integer	2	R	0x00000000-0xFFFFFFFF	Time, Date of last zero action
	40742					Note: this register value is only updated when CLOG_CAL3_ZERO_STATUS register is read.
CLOG_CAL3_ZERO_OFFSET	40743	Float	2	R	< -1.0e6,1.0e6 >	Zero offset currently in use
	40744					Note: this register value is only updated when CLOG_CAL3_ZERO_STATUS register is read.
PANEL_TEMP	40800	Float	2	R	< -100.0,150.0 >	Current Enclosure Temperature, in deg C
	40801					
ATM_PRESS	40802	Float	2	R	< 0.0,250.0 >	Atmospheric pressure from sensor, in kPa
	40803					
CO2A_ZERO	40804	Float	2	R	< -1.0e6,1.0e6 >	CO2 analyser zero setting.
	40805					Note: this register is reset to 0.0 after power-up and gets set during ANALYZER_ZERO reaction state.
COOLER_TEMP	40806	Float	2	R	< -100.0,150.0 >	Cooler temperature, if measured, in deg C
	40807					
GCTRL_AIR_PRESS	40812	Float	2	R	< 0.0,250.0 >	Air pressure measured on the gas controller PCB [kPa]
	40813					
GCTRL_O2_PRESS	40814	Float	2	R	< 0.0,250.0 >	Oxygen pressure measured on the gas controller PCB [kPa]
	40815					
REACT_STREAM_VALVE	40816	integer	1	R	<0,6 >	Actual analysis reaction stream valve. 0 = no analysis on any stream valve 1 = analysis on stream 1 valve 2 = analysis on stream 2 valve 3 = analysis on stream 3 valve 4 = analysis on stream 4 valve 5 = analysis on stream 5 valve 6 = analysis on stream 6 valve

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
REACT_RANGE	40817	integer	1	R	<0,3 >	Actual analysis reaction range. 0 = no analysis reaction 1 = analysis reaction range 1 2 = analysis reaction range 2 3 = analysis reaction range 3
ACID_RGNT_STATUS	40818	integer	1	R	< 0,999 >	Estimation of days remaining for Acid
BASE_RGNT_STATUS	40819	integer	1	R	< 0,999 >	Estimation of days remaining for Base
REACT_CNTR	40824	integer	2	R	0x00000000- 0xFFFFFFFF	Reaction counter.
	40825					
SERVICE_REQ	40826	integer	1	R	0x0000-0xFFFF	Service required in xxx days



Be Right™

B7000i & B7000i Dairy BioTector TOC Analyzer V 1.1 ERROR Registers

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
SYS_ALARM_STATUS	49930	integer	1	R	0x0000-0x000F	Alarm Status. Bitwise coding: bit 0 = fault. bit 1 = warning. bit 2 = notification. Bit 3 = DW warning.
SYS_COND_GRP	49950	integer	1	R	0x0000-0xFFFF	bit 0 = fault archive code 01, Low O2 Flow - EX bit 1 = fault archive code 02, Low O2 Flow - SO ..bit 15 Note: For description of Fault Archive codes please refer to User Manual Section "Troubleshooting of System Faults, Warnings and Notification Events"
SYS_COND_GRP	49951	integer	1	R	0x0000-0xFFFF	bit 0 = fault archive code 17, bit 1 = fault archive code 18, ..bit 15 Note: For description of Fault Archive codes please refer to User Manual Section "Troubleshooting of System Faults, Warnings and Notification Events"
	
SYS_COND_GRP	49966	integer	1	R	0x0000-0xFFFF	bit 0 = fault archive code 241, bit 1 = fault archive code 242, ..bit 15 Note: For description of Fault Archive codes please refer to User Manual Section "Troubleshooting of System Faults, Warnings and Notification Events"

B7000i & B7000i Dairy BioTector TOC Analyzer V 1.1 STATUS & EXTERNAL CONTROL Registers

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
SYS_OP_STATUS	49931	integer	1	R	0x0000-0x003F	Operational Status. Bitwise coding: bit 0 = running. bit 1 = manual running. bit 2 = calibration running. bit 3 = zero running. bit 4 = remote standby activated. bit 5 = maintenance switch activated.
SYS_REM_CTRL	49932	integer	1	R/W	<0,7>	System remote control. 0 = no change 1 = system finish & stop 2 = analysis start 3 = zero cal start 4 = zero check start 5 = span cal start 6 = span check start 7 = reagents purge and zero
SYS_REM_CTRL_STANDBY	49933	integer	1	R/W	< 0,1 >	Set Remote Standby function. 0 = Modbus remote standby deactivated 1 = Modbus remote standby activated Note: the content of this register is internally OR'd with REMOTE STANDBY digital input line (if this one is available in the system).
SYS_REM_CTRL_SYNC	49934	integer	1	R	< 0,1 >	Synchronization output for remote control operation Note: works even without SYNC output defined in system.
SYS_REM_CTRL_RANGE	49935	integer	1	R/W	< 0,3 >	Select next range 0 = not selected / auto 1 = range 1 2 = range 2 3 = range 3 Note: if this register value is 0 then range is selected by EXT_RANGE_MUX1-2 digital input lines (if these one are available in the system). otherwise the content of this register takes precedence over the digital input lines.

NAME	REGISTER	DATA TYPE	LENGTH	ACCESS MODE	MIN/MAX	DESCRIPTION
SYS_REM_CTRL_STREAM	49936	integer	1	R/W	0x0000-0x007f	<p>Next stream to be selected: bit 0 = Stream 1. bit 1 = Stream 2. bit 2 = Stream 3. bit 3 = Stream 4. bit 4 = Stream 5. bit 5 = Stream 6.</p> <p>Note: the content of this register is internally OR'd with STREAM SEL 1-6 digital input lines to activate/deactivate particular stream selection</p>
SYS_DEBUG_MODE	45000	integer	1	R/W	0x0000-0x0001	<p>System debug mode register.</p> <p>0 – normal system operation 1 – system supplies pre-defined Modbus registers values</p>